(ख) यदि हां, तो एजेंसी के आबंटन के लिये कितने आवेदन प्राप्त हुए थे ;

(ग) इस एजेंसी को आरम्भ करने में विलम्ब होने के क्या कारण हैं ; और

(घ) इस क्षेत्र में गैस कनेक्शन की सुविधा कब तक उपलब्ध करा दिये जाने की संभावना है ?

पैट्रोलियम और प्राकृतिक गैस मंत्रालय के राज्य मंत्री तथा वित्त मंत्रालय में राज्य मंत्री (श्री ब्रह्म दत्त) : (क) और (ख) बसौदा में एल पी जी वितरणशिप के आबंटन के लिए 13 सितम्बर, 1984 को विज्ञापन दिया गया था, जिसके अनुसरण में 29 आवेदन प्राप्त हुए थे ।

(ग) और (घ) इंडियन आयल कारपोरेशन द्वारा चुने हुए उम्मीदवार को आशय पत्र जारी नहीं किया जा सका है क्योंकि तेल चयन बोर्ड ने अभी तक नामों का पैनल नहीं भेजा है । इस बोर्ड की समयावधि जून, 1986 में समाप्त हो गई है, शीघ्र ही इसका पुनर्गठन किए जाने की संभावना है । आमतौर पर एक उम्मीदवार को वितरणशिप चालू करने के लिए प्रबन्धों और आवश्यक औपचारिकताएं पूरी करने के लिए आशय पत्र जारी करने की तिथि से चार माह का समय दिया जाता है ।

Demand and supply of electricity

8. DR. MOHD. HASHIM KIDWAI: Will the Minister of ENERGY be pleased to state:

(a) what hag been the State-wise average of demand and supply position of electricity in the country from January, 1988 to January, 1987;

(b) what has been the State-wise position of power break down in the country during the year 1086-87 and •what are the reasons therefor; and

(c) what are the details of the stePs taken by Government *to* improve the situation?

319 RS—3.

THE MINISTER OF STATE IN THE DEPARTMENT OF POWER IN THE MINISTRY OF" ENERGY" (SHRIMATI SUSHILA ROHATGI); (a) The required information is given in the enclosed statement. (See below)

(b) Available information about the major power breafc-downs affecting the entire region or an entire State during 1980-87 is given below: —

Northern Region

(i) On 3-4-86 Affecting Delhi, Haryana, Rajasthan.

(ii) On 26-6-86 Affecting Western U. P. and Delhi.

(iii) On 29-6-86 Affecting the en tire U. P.

Western Region

(i) On 30-12-86 Affecting the entire Bihar.

(ii) On 20-1-87 Affecting the entire DVC,

Western Region/Southern Region

There were no cases of failure of complete State Systems/regional grid during *1986-87?,*

North-Eastern Region

There were 22 "instances of short duration interruptions! of power supply in Assam and 9 in Megha-laya.

There are variou$_s$ reasons for major breakdowns such 8s tripping of major transmission lines, forced outages of large generating Units, failure/malfunctioning of protection equipment, etc.

(c) In order to improve the power availability, variou$_s$ steps have been taken which include expediting commissioning of new capacity, better utilisation of existing capacity, implementing short gestation projects, reducing transmission and distribution

losses, implementation of energy conservfltiin and demand management measures and arranging transfer of energy from surplus to deficit States.

statement

Power Supply Position for January, 1985 *to January,* 1987

Region/State/System	Require, ment	[All figu Availabi- lity	res (in MW) net] Shortage	Percentag
Northern Region				
Chandigarh.	795	758	37	4. 7
	10789	10776	13	0. 1
	11963	9417	2546	21. 3
Himachal Pradesh....	. 1720	1712	8	05
Jammu & Kashmir	3827	3234	593	155
Paunjab incl. NFF	22532	20919	1613	7. 2
Rajasthan...	15718	14233	1485	9. 4
Uttar Pradesh. . . .	38673	33384	5289	13. 7
TOTAL.	106017	94433	11584	10. 0
Western Region Gujarat.....	30863	30064	799	2. 6
M. P	24523	24508	15	01
Maharashtra incl. Goa.	56160	54001-	2159	38
TOTAL.	111546	108573	2973	27
Southern Region				
Andhra Pradesh...	29242	29242		
	26483	20321	6162	23. 3
Kerala..	11090	10664	426	3. 8
Tamil Nadu. . . .	31794	28674	3120	96
TOTAL.	98609	88901	9708	98
Eastern Region				
	9479	6776	2703	28. 5
D. V. C...	14068	12110	1958	13. 9
	12033	9451	2582	21. 5
West Bengal. . . .	16164	14971	1193	7-4
TOTAL.	51744	43308	8436	16 3
North Eastern Region Total.....	3789	3594	195	51
	371705	338809	32896	8. 9